

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME****CB TEST CERTIFICATE**

| | |
|---|--|
| Product | Residual current operated circuit-breakers with integral overcurrent protection (RCBOs) |
| Name and address of the applicant | ETI Elektroelement d.o.o. Obrezija 5, 1411 Izlake Slovenia |
| Name and address of the manufacturer | ETI Elektroelement d.o.o. Obrezija 5, 1411 Izlake Slovenia |
| Name and address of the factory | <input type="checkbox"/> Additional information on page 2 ETI Elektroelement d.o.o. Obrezija 5, 1411 Izlake Slovenia |
| <i>Note: When more than one factory, please report on page 2</i> | |
| Ratings and principal characteristics | In: 6 A, 10 A, 13 A, 16 A, 20 A, 25 A, 32 A; I Δ n: 30 mA, 100 mA, 300 mA, 500 mA; Ue: 400/415 Vac; 3P+N; type B, C; type A, AC (30 mA); without time delay; Icn: 6 kA, Ics: 6 kA; I Δ m: 4,5 kA; safety distance: 40 mm; 50/60 Hz |
| Trademark (if any) | ETI |
| Customer's Testing Facility (CTF) Stage used | CTF Stage 2 |
| Model / Type Ref. | KZS-4M |
| Additional information (if necessary may also be reported on page 2) | <input type="checkbox"/> Additional information on page 2 |
| A sample of the product was tested and found to be in conformity with | IEC 61009-1:2010, IEC 61009-1:2010/AMD1:2012, IEC 61009-1:2010/AMD2:2013, IEC 61009-2-1:1991 |
| As shown in the Test Report Ref. No. which forms part of this Certificate | 2235007.50 |

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands

