



# CB TEST CERTIFICATE

Ref. Certificate No.

NL-18030

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	KEMA Quality B.V.		
Product:	Residual current operated circuit-breakers with overcurrent protection		
Applicant:	ETI Elektroelement d.d.	Obrezija 5 01411, Izlake	Slovenia
Manufacturer:	ETI Elektroelement d.d.	Obrezija 5 01411, Izlake	Slovenia
Factory:	ETI Elektroelement d.d.	Obrezija 5 01411, Izlake	Slovenia
Rating and principal characteristics:	In = 6, 10, 13, 16, 20, 25 A; I $\Delta$ n = 30 mA; Ue = 230 Vac; 1P+N; type A and AC; without time delay; type B and C, Icn = 4,5 kA; Ics = 4,5 kA; I $\Delta$ m = 1,5 kA; safety distance "a" 40 mm; Uimp = 4 kV; 50 / 60 Hz;		
Trade mark (if any):	ETI		
Model/Type reference:	KZS-1M		
Additional information:	-		
Sample of product tested to be in conformity with IEC:	61009-1(ed.2);am1;am2 61009-2-2(ed.1)		
Test Report Ref. No:	2128487.52		

This CB Test Certificate is issued by the National Certification Body:

KEMA Quality B.V.  
Utrechtseweg 310  
P.O. Box 5185  
6802 ED Arnhem  
The Netherlands

**KEMA Quality**  
a DEKRA company

Signed by: H.R.M. Barends

Date of issue: 2010-05-04