

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Low-voltage fuse-holders for D-type fuse system (D02)

Name and address of the applicant

ETI Elektroelement d.d.
Obrezija 5,
1411 Izlake, Slovenia

Name and address of the manufacturer

ETI Elektroelement d.d.
Obrezija 5,
1411 Izlake, Slovenia

Name and address of the factory

ETI ELB s.r.o.
Potočna 42,
90084 Báhon, Slovakia

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

AC 400 V,
63 A, size: D02
1p, 3p

Trademark (if any)

ETI

Customer's Testing Facility (CTF) Stage used

--

Model / Type Ref.

PLK D02

Additional information (if necessary may also be reported on page 2)

Also found to be in conformity with IEC 60269-1:2006/AMD2:2014.

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60269-1:2006
IEC 60269-1:2006/AMD1:2009
IEC 60269-3:2010
IEC 60269-3:2010/AMD1:2013


As shown in the Test Report Ref. No. which forms part of this Certificate

SGP-05509/PLK D02T+PLK D02N/CB/1,
SGP-05509/PLK D02T+PLK D02N/CB/3

This CB Test Certificate is issued by the National Certification Body



AUSTRIAN ELECTROTECHNICAL ASSOCIATION

Kahlenberger Str. 2A
1190 Wien, Austria
Signature: Dipl.-Ing. W. MartinDigitally signed by W. Martin
Email=w.martin@ove.at

Date: 2017-05-31

ZVR: 327279890 | DVR: 1055887