

# KEMA TYPE TEST CERTIFICATE OF BREAKING PERFORMANCE

<b>Object</b>	HV current-limiting back-up fuse-links with a striker pin		<b>5070-20</b>		
<b>Type</b>	VVT TD3	<b>Serial No.</b>	-		
<b>Designation</b> (length = 292 mm)	Rated voltage kV	Rated maximum breaking current kA	Rated current A	Rated minimum breaking current A	Rated frequency Hz
VVT TD3	12	63	10	43	50
<b>Manufacturer</b>	ETI d.o.o., Obrezija 5, 1411 - Izlake, Slovenia *)				
<b>Client</b>	ETI d.o.o., Obrezija 5, 1411 - Izlake, Slovenia				
<b>Tested by</b>	KEMA Laboratories Prague Zkušebnictví, a.s., Podnikatelská 547, Prague 9, The Czech Republic				
<b>Date of tests</b>	27 and 29 April 2020				

The object, constructed in accordance with the description, drawings and photographs incorporated in this Certificate, has been subjected to the series of proving tests in accordance with

**IEC 60282-1:2020** subclause 7.6 (Breaking tests)

This Certificate has been issued by KEMA Labs following exclusively the STL Guides.

The results are shown in the record of proving tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above standard(s) and to justify the ratings assigned by the manufacturer as listed on page 5.

This Certificate applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the Manufacturer.

\*) as declared by the manufacturer

This Certificate consists of 41 pages in total.

Zkušebnictví, a.s.



Robert Jech  
Operational Manager

Prague, 17 July 2020