

KEMA TYPE TEST CERTIFICATE OF BREAKING PERFORMANCE

Object	HV current-limiting back-up fuse-links with a striker pin		5072-20		
Type	VVT TD3	Serial No.	-		
Designation (length = 442 mm)	Rated voltage kV	Rated maximum breaking current kA	Rated current A	Rated minimum breaking current A	Rated frequency Hz
VVT TD3	24	63	10	42	50
Manufacturer	ETI d.o.o., Obrezija 5, 1411 - Izlake, Slovenia *)				
Client	ETI d.o.o., Obrezija 5, 1411 - Izlake, Slovenia				
Tested by	KEMA Laboratories Prague Zkušebnictví, a.s., Podnikatelská 547, Prague 9, The Czech Republic				
Date of tests	28 and 29 April 2020				

The object, constructed in accordance with the description, drawings and photographs incorporated in this Certificate, has been subjected to the series of proving tests in accordance with

IEC 60282-1:2020 subclause 7.6 (Breaking tests)

This Certificate has been issued by KEMA Labs following exclusively the STL Guides.

The results are shown in the record of proving tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above standard(s) and to justify the ratings assigned by the manufacturer as listed on page 5.

This Certificate applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the Manufacturer.

*) as declared by the manufacturer

This Certificate consists of 40 pages in total.

Zkušebnictví, a.s.



Robert Jech
Operational Manager

Prague, 17 July 2020