



产品认证证书

证书编号: CQC2011010308466421

II 型自愿认证

申请人名称及地址

Jean Mueller GmbH Elektrotechnische Fabrik
H. J.-Mueller-Strasse7, 65343 Eltville am Rhein, Germany

制造商名称及地址

Jean Mueller GmbH Elektrotechnische Fabrik
H. J.-Mueller-Strasse7, 65343 Eltville am Rhein, Germany

生产企业名称及地址

ETI Elektroelement d. o. o. (V045351)
Obrezija 5, 1411 Izlake Slovenia

产品名称和系列、规格、型号

半导体设备保护用熔断体

G3üf0, G3Müf0; 熔断

体:Un:AC690V, AC1000V; In:630A, 710A, 800A, 900A, 1000A, 1250A, 1400A/AC690V;
In:500A, 630A, 710A, 800A, 1000A/AC1000V; 额定分断能力:100kA; 分断范围和使用类别:aR

产品标准和技术要求

GB/T 13539.4-2016

认证模式

产品型式试验+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

发证日期: 2020 年 12 月 22 日 有效期至: 2030 年 12 月 22 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2020 年 09 月 23 日

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0408648



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2011010308466421

Type II CQC Certification

NAME AND ADDRESS OF THE APPLICANT

Jean Mueller GmbH Elektrotechnische Fabrik
H.J.-Mueller-Strasse7,65343 Eltville am Rhein, Germany

NAME AND ADDRESS OF THE MANUFACTURER

Jean Mueller GmbH Elektrotechnische Fabrik
H.J.-Mueller-Strasse7,65343 Eltville am Rhein, Germany

NAME AND ADDRESS OF THE FACTORY

ETI Elektroelement d.o.o. (V045351)
Obrezija 5, 1411 Izlake Slovenia

PRODUCT NAME, MODEL AND SPECIFICATION

Fuse-links for semiconductor protection

G3üf0,G3Müf0; Fuse link:Un:AC690V,AC1000V;In:630A,710A,800A,900A,1000A,1250A,
1400A/AC690V;In:500A,630A,710A,800A,1000A/AC1000V;Rated breaking capacity: 100kA;Breaking Range and Utilization
Category:aR

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 13539.4-2016

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification
rules of CQC12-000001-2020 .

Valid from: Dec.22,2020

Valid until: Dec.22,2030

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing
certification body until the expiry date.

Date of original issued: Sep.23,2020

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0408648